



International Journal Of
**Recent Scientific
Research**


ISSN: 0976-3031
Volume: 7(5) May -2016

ENERGY ESTIMATION: A CASE STUDY OF UNIVERSITY

Lakshminarayana G and Jayatheertha HJ



THE OFFICIAL PUBLICATION OF
INTERNATIONAL JOURNAL OF RECENT SCIENTIFIC RESEARCH (IJRSR)
<http://www.recentscientific.com/> recentscientific@gmail.com



ISSN: 0976-8031

Available Online at <http://www.recentscientific.com>

International Journal of Recent Scientific Research
Vol. 7, Issue, 5, pp. 11258-11260, May, 2016

**International Journal of
Recent Scientific
Research**

Research Article

ENERGY ESTIMATION: A CASE STUDY OF UNIVERSITY

Lakshminarayana G* and Jayatheertha HJ

EEE Department, GITAM University, Hyderabad Campus Telangana State, India

ARTICLE INFO

Article History:

Received 05th February, 2016
Received in revised form 21st March, 2016
Accepted 06th April, 2016
Published online 28th May, 2016

Keywords:

Building energy estimation; list of energy conservation measures; identification of low cost improvements

ABSTRACT

Preliminary Energy estimation analysis is made to assess Gandhi Institute of Technology and Management University to identify not only simple and low cost improvements but also a list of energy conservation measures or energy conservation opportunities to orient the future detailed energy audit.

Copyright © Lakshminarayana G and Jayatheertha HJ., 2016, this is an open-access article distributed under the terms of the Creative Commons Attribution License, which permits unrestricted use, distribution and reproduction in any medium, provided the original work is properly cited.

INTRODUCTION

Energy audits initially became popular in response to the energy crisis of 1973 and later years. Interest in energy audits has recently increased as a result of growing understanding of human impact upon global warming and climate change. Energy audits are also popular due to financial incentives for homeowners. Generally, four levels of analysis can be outlined: [1]

- Level 0 – Benchmarking: This first analysis consists in a preliminary Whole Building Energy Use (WBEU) analysis based on the analysis of the historic utility use and costs and the comparison of the performances of the buildings to those of similar buildings [2]
- Level I – Walk-through audit: Preliminary analysis made to assess building energy efficiency to identify not only simple and low- cost improvements but also a list of energy conservation measures (ECMs, or energy conservation opportunities, ECOs) to orient the future detailed audit.[3]
- Level II – Detailed/General energy audit: Based on the results of the pre-audit, this type of energy audit consists in energy use survey in order to provide a comprehensive analysis of the studied installation, a more detailed analysis of the facility, a breakdown of the energy use and a first quantitative evaluation of the ECOs/ECMs

selected to correct the defects or improve the existing installation.[4]

- Level III – Investment-Grade audit: Detailed Analysis of Capital-Intensive Modifications focusing on potential costly ECOs requiring rigorous engineering study.

The present case study is done on Level I – Walk- through audit

Energy Estimation

Table I First floor with energy estimation

| ROOM NO. | No. of Lights | Light Wattage | No. of Fans | Fan Wattage | Total wattage |
|----------|---------------|---------------|-------------|-------------|---------------|
| J201 | 10 | 10*95 | 10 | 10*80 | 1750 |
| J202 | 10 | 10*95 | 10 | 10*80 | 1750 |
| J203 | 10 | 10*95 | 10 | 10*80 | 1750 |
| J204 | 24 | 24*36 | 10 | 10*80 | 1664 |
| J205 | 10 | 10*95 | 10 | 10*80 | 1750 |
| J206 | 10 | 10*95 | 10 | 10*80 | 1750 |
| J211 | 27 | 27*24 | 0 | 0 | 648 |
| J212 | 7 | 7*95 | 8 | 8*80 | 1305 |
| J217 | 1 | 1*95 | 2 | 2*80 | 255 |
| J218 | 2 | 2*95 | 2 | 2*90 | 370 |
| J219 | 2 | 2*95 | 2 | 2*90 | 370 |
| J220 | 2 | 2*95 | 2 | 2*90 | 370 |
| J221 | 2 | 2*95 | 2 | 2*90 | 370 |
| J221T | 3 | 3*43 | 0 | 0 | 129 |
| J222T | 6 | 6*36 | 0 | 0 | 216 |
| J | | | | | |
| Director | 15 | 15*(95+36+36) | 3 | 3*80 | 2745 |
| Corridor | 39 | 39*43 | 3 | 3*80 | 1917 |
| | | | | TOTAL | 19109 |

*Corresponding author: Lakshminarayana G
EEE Department, GITAM University, Hyderabad Campus Telangana state, India

First floor energy estimation given in Table 1

Floor energy estimation

Table II Third floor with energy estimation

| ROOM NO. | No. of Lights | Light Wattage | No. of Fans | Fan Wattage | Total wattage |
|--------------|---------------|---------------|-------------|-------------|---------------|
| J401 | 7 | 7*95=665 | 10 | 10*80=800 | 1465 |
| J402 | 9 | 9*95=855 | 10 | 10*80=800 | 1665 |
| J403 | 9 | 9*95=855 | 10 | 10*80=800 | 1665 |
| J404 | 9 | 9*95=855 | 10 | 10*80=800 | 1665 |
| J405 | 9 | 9*95=855 | 10 | 10*80=800 | 1665 |
| J406 | 9 | 9*95=855 | 10 | 10*80=800 | 1665 |
| J411 | 13 | 13*95=1235 | 10 | 10*80=800 | 2035 |
| J412 | 5 | 5*95=475 | 5 | 5*80=400 | 875 |
| J413 | 5 | 5*95=475 | 4 | 4*80=320 | 795 |
| J415 | 1 | 1*43=43 | 1 | 1*80=80 | 123 |
| J416 | 1 | 1*43=43 | 1 | 1*80=80 | 123 |
| J417 | 6 | 6*95=570 | 12 | 12*80=960 | 1530 |
| J417T | 6 | 6*36=216 | 0 | 0 | 216 |
| J418T | 18 | 18*36=648 | 0 | 0 | 648 |
| J419 | 2 | 2*43=86 | 1 | 1*80=80 | 166 |
| J420 | 2 | 2*43=86 | 1 | 1*80=80 | 166 |
| J421A | 12 | 12*95=1140 | 8 | 8*80=640 | 1780 |
| J421B | 12 | 12*95=1140 | 8 | 8*80=640 | 1780 |
| J422A | 12 | 12*95=1140 | 8 | 8*80=640 | 1780 |
| J422B | 12 | 12*95=1140 | 8 | 8*80=640 | 1780 |
| CORRIDOR | 53 | 53*43=2279 | 0 | 0 | 2279 |
| TOTAL | | | | | 25866 |

Floor energy estimation

Table III Fourth floor with energy estimation

| ROOM NO. | No. of Lights | Light Wattage | No. of Fans | Fan Wattage | Total wattage |
|--------------|---------------|---------------|-------------|-------------|---------------|
| J501 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J502 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J503 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J504 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J505 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J506 | 8 | 8*95=760 | 10 | 10*80=800 | 1560 |
| J517T | 10 | 10*36=360 | 0 | 0 | 360 |
| A4 | 1 | 1*43=43 | 1 | 1*80 | 123 |
| A18 | 1 | 1*43=43 | 1 | 1*80 | 123 |
| J512 | 11 | 11*95=1045 | 10 | 10*80=800 | 1845 |
| J520A | 10 | 10*95=950 | 10 | 10*80=800 | 1750 |
| J520B | 11 | 11*95=1045 | 12 | 12*80=960 | 2005 |
| J521A | 10 | 10*95=950 | 10 | 10*80=800 | 1750 |
| J513 | 1 | 1*43=43 | 0 | 0 | 43 |
| J516 | 16 | 16*43=688 | 10 | 10*80=800 | 1488 |
| J521B | 12 | 12*95=1140 | 10 | 10*80=800 | 1940 |
| J522 | 12 | 12*43=516 | 4 | 4*80=320 | 836 |
| J516T | 6 | 6*36=216 | 0 | 0 | 216 |
| A5 | 1 | 1*95=95 | 1 | 1*80 | 175 |
| CORRIDOR | 31 | 31*43=1333 | 0 | 0 | 1333 |
| TOTAL | | | | | 23822 |

Floor energy estimation

Energy Conservation Measure At Corridors

As shown in Figure 1 and Table V it can be seen that only one bulb glows when the main switch S is on. Similarly we can use the modified circuit in figure1 to accommodate say 36 tube lights and 33 two way switches in between S1 and S2 so that only one tube glows at a given instant of time as given in figure 2. Layout diagram for the first circuit in fig.1 is given in fig 3.

Total corridor tube light wattage =1917+2279+1333 +1677=7206 watts

Total corridor wattage with energy conservation=43*4=172 watts

Power saved= 7206-172=7034 watts

Ratio of energy saved=97.6%

Table IV Fifth floor with energy estimation

| ROOM NO. | No. of Lights | Light Wattage | No. of Fans | Fan Wattage | Total wattage |
|--------------|---------------|---------------|-------------|-------------|---------------|
| J601 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J602 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J603 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J604 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J605 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J606 | 9 | 9*95=855 | 10 | 10*80=800 | 1655 |
| J612 | 5 | 5*95=475 | 12 | 12*80=960 | 1435 |
| J613 | 1 | 1*43=43 | 0 | 0 | 43 |
| J614 | 1 | 1*43=43 | 1 | 1*80=80 | 123 |
| J615 | 1 | 1*43=43 | 1 | 1*80=80 | 123 |
| J616 | 15 | 15*43=645 | 12 | 12*80=960 | 1605 |
| J616T | 6 | 6*36=216 | 0 | 0 | 316 |
| J617T | 10 | 10*36=360 | 0 | 0 | 360 |
| J618 | 1 | 1*43=43 | 1 | 1*80=80 | 123 |
| J619 | 1 | 1*43=43 | 0 | 0 | 43 |
| J620A | 7 | 7*95=665 | 8 | 8*80=640 | 1285 |
| J620B | 8 | 8*95=760 | 8 | 8*80=640 | 1400 |
| J621A | 10 | 10*95=950 | 10 | 10*80=800 | 1750 |
| J621B | 8 | 8*95=760 | 8 | 8*80=640 | 1400 |
| J622A | 10 | 10*95=950 | 10 | 10*80=800 | 1750 |
| J622B | 8 | 8*95=760 | 8 | 8*80=640 | 1400 |
| CORRIDOR | 39 | 39*43=1677 | 0 | 0 | 1677 |
| TOTAL | | | | | 24763 |




Figure1: Corridor with three bulbs




Figure 2: Corridor with n number of bulbs where n=3




Figure 3: Layout diagram for circuit1

Table V. switching results of corridor with three bulbs

| S | S1 | S2 | Bulb1 | Bulb2 | Bulb3 |
|-----|------|------|-----------|-----------|-----------|
| off | 1/1' | 2/2' | Not glows | Not glows | Not glows |
| on | 1' | 2/2' | glows | Not glows | Not glows |
| on | 1 | 2' | Not glows | glows | Not glows |
| on | 1 | 2 | Not glows | Not glows | Glows |

Observations of Energy Conservation

Switch off lights and fans if they are not in use. During winter and rainy seasons as we have good temperature fans need not turn on and during summer doors of class rooms can be opened in order to get good illumination from sun. Number of lights fixed in corridor is more as we need not require those many lights because we stay in college only from morning to evening so the number of lights can be reduced. The same thing we observed in staffrooms.

Illumination levels and improvements

In each class there are 18 tube lights placed in front, middle and on either sides of the classroom but there are no tube lights at backside where the illumination at last benches is low compared with the front and middle benches.

The illumination for a reading room is 250lux. On our observation we found the illumination level is equal to practical value at first benches and less at middle benches but at last benches it was quite less.

On either sides of the classroom the total number of tube lights are 12 in one class and in other classroom the number of tube lights are 8 but we observed the illumination at first bench in both classes is same. So we can place the 4 tube lights at backside to get better illumination rather than at front.

CONCLUSION

Energy estimation is done for GITAM University Hyderabad campus. A list of energy conservation measures is identified.

Acknowledgment

The authors are grateful to the kind authority of management and staff of Hyderabad campus for their valuable support.

References

1. www.keralaenergy.gov.in/pdf/EMC%20Energy%20Audit%20Draft%20Manual.pdf
2. <https://beeindia.gov.in/sites/default/files/1Ch3.pdf>
3. www.serviciocale.md/public/files/Energy_Management_Handbook.pdf
4. www.bsr.org/reports/bsr-energy-management-handbook.pdf

How to cite this article:

Lakshminarayana G and Jayatheertha HJ.2016, Energy Estimation: A Case Study of University. *Int J Recent Sci Res.* 7(5), pp. 11258-11260.

T.SSN 0976-3031



9 770976 303009 >